



HAINES BOROUGH, ALASKA

P.O. BOX 1209, HAINES, ALASKA 99827
Administration 907.766.2231 ♦ (fax) 907.766.2716
Tourism 907.766.2234 ♦ (fax) 907.766.3155
Police Dept. 907.766.2121 ♦ (fax) 907.766.2190
Fire Dept. 907.766.2115 ♦ (fax) 907.766.3373

December 16, 2009

TO ALL BID DOCUMENT HOLDERS

First Avenue, Willard Street, and Ocean View Drive Water System Upgrade

The following addendum was issued today. Please acknowledge receipt of the addendum on your bid documents. If you have already submitted your bid, you may fax a new page 00300-1 to the Clerk's Office (see Addendum Item No. 1). Thank you.

Sincerely,

A handwritten signature in cursive script that reads "Jamie Heinz".

Jamie Heinz
Deputy Clerk

ADDENDUM NUMBER 2 TO THE CONTRACT

for the

**Haines Borough, Alaska
First Avenue, Willard Street, and Ocean View Drive Water System Upgrade**

ADDENDUM NO.: Two

NEW (REVISED) BID OPENING DATE:

December 22, 2009

4:00 p.m. Local Time

PREVIOUS ADDENDA: One

ISSUED BY:

Haines Borough
103 Third Avenue
Haines, Alaska 99827


DATE ADDENDUM ISSUED:

December 16, 2009

The following items of the Contract are modified as herein indicated. All other items remain the same.

PROJECT MANUAL

- Item No. 1 Section 00300, BID, Page 2, under "TO BE CONSIDERED, ALL BIDDERS MUST INCLUDE THE FOLLOWING AT THE TIME OF THE BID OPENING" **ADD** 6. Completed "Disadvantage Business Enterprises (Minority and Women-Owned Business Enterprises) Compliance Statement" form from Section 00400 DBE, EEO AND AFFIRMATIVE ACTION. This form and Page 00300-1 acknowledging the addenda may be faxed to the Haines Borough at 907-766-2716 in accordance with the requirements for a faxed Modification of Bids as described in Section 00100 INSTRUCTIONS TO BIDDERS.
- Item No 2 Drawing G-3 DETAILS, WATER SERVICE DETAIL STANDARD 406 **DELETE** Notes 2, 3 and 4 and **REPLACE** them with the following: "2. Corp Stop shall be a Mueller Corporation Stop B25028.", "3. Curb Stop shall be a Mueller Curb Stop H15219 1" with drain.", "4. Curb Box shall be a Mueller No. H10306 with Stationary Rod No. 84341." and 12. Substitute similar Mueller products for copper service line sizes other than 1".
- Item No 3 Page 00030-1, Notice Inviting Bids, Receipt of Bids: **DELETE** 12:00 Noon, Friday December 18, 2009 and **REPLACE** with "4:00 p.m., Tuesday, December 22, 2009."

By: 
Julie Cozzi, Borough Clerk

Total number of pages contained within this Addendum: 1